



**Pollution Control Board:: Assam
Bamunimaiadam, Guwahati-21**

PUBLIC NOTICE

No. WB/G-295/21-22/284

Dated Guwahati the 11th August, 2023

Sub: Directions to Hotels, Health Care Facilities and Automobile Service Stations in the State.

All the Hospitals, Hotels, Resorts and Automobile Service Centres in the State are hereby directed to install a Treated Water Storage Tank (TWST) with a minimum capacity of 10 KL to store the treated water from the ETP/STP by October 15, 2023. The tank may be installed either over ground or underground. There should not be any bypass system of the ETP and treated water should be routed mandatorily into the TWST from which the Board shall collect samples for verification of compliance and examine the adequacy of the ETP. All the units must install flow meter at the discharge line from the TWST and records must be maintained accordingly.

Failing to comply with the above condition shall attract a minimum environmental compensation fine of Rs. 5000/- per day w.e.f. October 02, 2023.

(Shantanu Kr. Dutta)
Member Secretary

Memo No. WB/G-295/21-22/284-A,

Dated Guwahati the 11th August, 2023

Copy to:

1. The all Regional Heads, ROs, PCBA.
2. P.A. to the Chairman, PCBA for kind appraisal of the Hon'ble Chairman.
3. WhatsApp – Parivesh Asom group/Website/Social Media Platform of PCBA.

Member Secretary