

Format for Quotation / Price Bid

Quotation Notice No. WB/G-1384/17-18/05 dtd. 25.08.2017

Name of Work: Electrification for Shifting of UPS from 1st Floor (existing position) at Head Office, Pollution Control Board, Assam, Bamunimaidam, Guwahati-21 to 4th Floor of the same building to earmarked room (East South Side)"

Sl. No.	SOR Item No.	Description of item	Unit	Qty	Rate (Rs.)		Amount (Rs.)
					In figure	In words	
1	1.8	Wiring for drawing sub-main line with P.V.C. insulated single core unsheathed industrial (Multistrand) cable HFFR/ZHFR conforming to IS-694: 1990 with flexible bright annealed electrolytic copper conductor for voltage grade up to 1100 volts (Finolex /RR Kabel /Nicco or Equivalent Make as approved by the Deptt.) in surface flat ISI marked casing 'n' capping (AKG / Precision/ Presto Plast/Polycab/ MW or equivalent make as approved by the Deptt.) including earth continuity.					
	1.8.1	With 2 x 2.5 sq. mm. + earth continuity with 1x1.5 sq. mm. in surface flat 19 mm casing system	Metre	85			
2	1.10	Wiring for drawing sub-main line with P.V.C. insulated single core unsheathed industrial (Multistrand) cable HFFR/ZHFR conforming to IS-694: 1990 with flexible bright annealed electrolytic copper conductor for voltage grade up to 1100 volts (Finolex /RR Kabel /Nicco or Equivalent Make as approved by the Deptt.) in surface flat ISI marked casing 'n' capping (AKG / Precision/ Presto Plast/Polycab/ MW or equivalent make as approved by the Deptt.) including earth continuity.					
	1.10.5	With 4 x 16 sq. mm. + earth continuity with 2x10 sq. mm. cable in surface flat 32 mm ISI marked casing 'n' capping system,	Metre	72			
3	5.8	Wiring for circuit wiring with P.V.C. insulated single core unsheathed industrial flexible cable conforming to IS-694: 1990 with flexible bright annealed copper conductor for voltage grade up to 1100 volts (Finolex /RR Kabel /Nicco / Anchor or Equivalent Make as approved by the Deptt.) in surface/ recessed ISI marked Steel conduit pipe (AKG or equivalent as approved by the Deptt.) wiring system.					

Sl. No.	SOR Item No.	Description of item	Unit	Qty	Rate (Rs.)		Amount (Rs.)
					In figure	In words	
	5.8.7	With 4 x 35 sq. mm. + earth continuity with 2x25 sq. mm. cable in 50 mm. dia. rigid Steel conduit.	Metre	72			
4	14.3	Supplying with fitting and fixing sheet steel, phosphatised, powder painted Single door surface mounting MCB enclosure incorporated with bus-bar, Neutral link, Earth bar and din rail etc fitted on wall with grouting nuts & bolts as reqd. complete with making necessary connection as approved, specified and directed by the deptt.					
	14.3.14	4 way single door	Each	7			
5	16.13	Supplying with fitting and fixing panel mounting open execution 25 KA 415V 50Hz 3P MCCB (Ics=Icu, adjustable Ir setting 0.7) without enclosure of the following capacity complete with making necessary connection as approved by the Deptt. as specified and directed by the deptt.					
	16.13.1.1	16A	Each	6			
	16.13.1.6	100A	Each	1			
Total (Rs.)							

Submitted by:
(Name & Address)